



- NOTES
- WHERE REQUIRED, CONTRACTOR SHALL DREDGE TRENCH IN RIVER BOTTOM AND REMOVE ALL SPOIL MATERIAL TO A LEGAL DISPOSAL AREA.
 - DIFFUSER SECTION AND PIPING SHALL BE PRESSURE TESTED PRIOR TO INSTALLING BELOW WATER LINE.
 - U.S. ARMY C.O.E./T.V.A. SHALL BE NOTIFIED TWO WEEKS PRIOR TO COMMENCING CONSTRUCTION WITHIN THE RIVER BEVERLYMANATION ALL TIMES. CONTRACTOR SHALL PROVIDE ALL WARNING MARKERS, BARRICADES AS MAY BE REQUIRED BY THE C.O.E./T.V.A.
 - ALL FEDERAL, STATE, AND LOCAL REGULATIONS AND PERMIT REQUIREMENTS MUST BE COMPLIED WITH AT ALL TIMES.
 - ALL INFORMATION SHOWN IS PRELIMINARY, BASED ON AVAILABLE INFORMATION. FINAL CONFIGURATION WILL BE BASED ON WATER QUALITY MODEL.

2 DREDGING SECTION
SCALE: NONE

3 SECTION - DIFFUSER PORT
SCALE: NONE

4 SECTION - CONCRETE WEIGHTS
SCALE: NONE

5 SECTION - CONCRETE WEIGHTS
SCALE: NONE



Figure 2-8

Diffuser

Sections And Details

Earth Tech Company LLC
Southeast Barton, Alabama Facility
Proposed Barton, Alabama Facility
September 2002